



This document is the translation of the French certificate n° 16-00242 L on the 2<sup>nd</sup> February, 2016 delivered by IFTH.

## MATERIAL REACTION TO FIRE CLASSIFICATION REPORT

prepared in compliance with amended 5 of the French Home Office Regulation  
dated November 21<sup>st</sup>, 2002 (Official Gazette dated December 31, 2002)

Valid five years from issue date

**CERTIFICATE N° 16-00242 L**

And appendices of 4 pages

**MATERIAL presented by :**

MERMET SAS  
58 Chemin Du Mont Maurin  
38630 VEYRINS THUELLIN  
FRANCE

**TRADE NAME :**

KIBO 8500

**BRIEF DESCRIPTION :**

Fiberglass yarns coated with PVC covered on one side with acrylo-vinyl coating  
and white flock  
Nominal surface weight : 590 to 650 g/m<sup>2</sup>  
Measured thickness : around 0.50 to 0.55 mm  
Colours : various

**TEST REPORT :**

N° 16-00242 E1-V2 on the 2<sup>nd</sup> February, 2016

**TESTS :**

Electrical burner test

**CLASSIFICATION :**

**M 1**

**CLASSIFICATION DURATION (article 5 of appendix 2):**

unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France on the 2<sup>nd</sup> February, 2016

Head of Quality Management Test and trials  
Jean-Marc ORAISON



ACCREDITATION  
N° 1-0101 et  
N° 1-0513  
PORTÉE  
COMMUNIQUÉE  
SUR DEMANDE